



**PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT**

Amendments for 2015 IFC

**CHAPTER 1
SCOPE AND ADMINISTRATION**

Section 101.2.1 Appendices. All appendices to be adopted

Section 113.2 Schedule of permit fees. Is AMENDED to read:

A fee for each permit shall be paid, as required, in accordance with the schedule as established by the Pinetop Fire District/Timber Mesa Fire and Medical District fee schedule.

**CHAPTER 2
DEFINITIONS**

Driveway. Is ADDED to read:

Driveway. A vehicular ingress and egress route that serves no more than five buildings or structures, not including accessory structures, or no more than five residential dwelling units.

Institutional Group I-1. The first sentence is AMENDED to read:

Institutional Group I-1 occupancy shall include buildings, structures or parts thereof for more than 10 persons, excluding staff, who reside on a 24-hour basis in a supervised environment and receive custodial care.



PINETOP FIRE DEPARTMENT

TIMBER MESA FIRE AND MEDICAL DISTRICT

Institutional Group I-1, Six to Sixteen persons receiving custodial care. Is AMENDED to read:

Six to ten persons receiving care. A facility such as above, housing not fewer than six and not more than 10 persons receiving such care, shall be classified as Group R-4.

Residential Group R-3. AMENDED to read:

Residential occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, R-4 or I, including:
Boarding houses (transient or non-transient) with 10 or fewer occupants,
Buildings that do not contain more than two *dwelling units*,
Care facilities that provide accommodations for five or fewer persons receiving care,
congregate living facilities (transient or non-transient) with 10 or fewer occupants.

Residential Group R-4. The first sentence is AMENDED to read:

Residential Group R-4 shall include buildings, structures or portions thereof for more than five but not more than 10 persons, excluding staff, who reside on a 24-hours basis in a supervised residential environment and receive custodial care.

CHAPTER 3

GENERAL REQUIREMENTS

Section 311.5 Placards. Is AMENDED to read:

When determined by the fire or building code official, any vacant or abandoned buildings or structures determined to be unsafe pursuant to Section 110 of this code relating to structural or interior hazards shall be marked as required by Sections 311.5.1 through 311.5.5.



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

CHAPTER 5
FIRE SERVICE FEATURES

Section 507.5.4 Obstruction. Is AMENDED by ADDING a third sentence:

Unobstructed access to fire hydrants shall be maintained at all times. The fire department shall not be deterred or hindered from gaining immediate access to fire protection equipment or fire hydrants. Vehicles shall not be placed, parked, or kept within 15 feet (4,572 mm) from the center of a fire hydrant, pursuant to A.R.S. 28-873 A(4).

CHAPTER 9
FIRE PROTECTION SYSTEMS

Section 901.2 Construction Documents. Is AMENDED by ADDING a second paragraph:

Automatic fire protection system hydraulic calculations shall be based upon 90 percent of the available water supply as determined by the local water purveyor or flow test information.

Section 901.4.6 Pump and riser room size. Is AMENDED to read:

Fire pump and *automatic sprinkler system* riser rooms shall be located in a dedicated room and have a door directly accessible from the exterior of the building in new construction. New *automatic sprinkler systems* that are installed in existing buildings are to have the riser room located within 100 feet of a door leading to the exterior of the building. The room shall be designed with adequate space for all equipment necessary for the installation, as defined by the manufacturer, with sufficient working space around the stationary equipment. Clearances



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

around the equipment to elements of permanent construction, including other installed equipment and appliances, shall be sufficient to allow inspection, service, repair or replacement

without removing such elements of permanent construction or disabling the function of a required fire-resistance-rated assembly. Fire pump and *automatic sprinkler system* riser rooms shall be

provided with a door(s) and an unobstructed passageway large enough to allow for removal of the largest piece of equipment.

Section 901.6.2 Records. Is AMENDED to read:

Records of all system inspections, tests and maintenance required by the referenced standards shall be maintained on the premises for a minimum of three years. All individuals or businesses performing inspections, tests or maintenance required by the referenced standards shall forward itemized reports of such work to the fire code official within 30 days of activity performed.

Section 903 - AUTOMATIC FIRE SPRINKLER SYSTEMS

Section 903.2.1.1 – Group A-1 is AMENDED to read:

1. The *fire area* exceeds 5,000 square feet (464.5152 m²).
2. The *fire area* has an occupant load of 150 or more.

Section 903.2.1.2 – Group A-2 is AMENDED to read:

1. The *fire area* exceeds 3,000 square feet (287.7091 m²).



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

Section 903.2.1.3 – Group A-3 is AMENDED to read:

1. The *fire area* exceeds 5,000 square feet (464.5152 m²).
2. The *fire area* has an occupant load of 150 or more.

Section 903.2.1.4 – Group A-4 is AMENDED to read:

1. The *fire area* exceeds 5,000 square feet (464.5152 m²).
2. The *fire area* has an occupant load of 150 or more.

Section 903.2.1.6 – Assembly occupancies on roofs is AMENDED to read:

Where an occupied roof has an assembly occupancy with an *occupant load* exceeding 50 for a group A-2 and 150 for other Group A occupancies, all floors between the occupied roof and the *exit level of discharge* shall be equipped with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or 903.3.1.2.

Section 903.2.3 Group E. Is AMENDED to read:

1. Throughout all Group E *fire areas* greater than in area.

Section 903.2.4 Group F-1. Is AMENDED to read:

1. A Group F-1 *fire area* exceeds 5,000 square feet (464.5152 m²).
2. A Group F-1 *fire area* is located more than two stories above grade plane.
3. The combined area of all Group F-1 *fire areas* on all floors, including any mezzanines, exceeds 10,000 square feet (929.0304 m²).



PINETOP FIRE DEPARTMENT

TIMBER MESA FIRE AND MEDICAL DISTRICT

Section 903.2.4.1. Is AMENDED to read:

An *automatic sprinkler system* shall provided throughout all Group F-1 occupancy *fire areas* that contain commercial woodworking operations in excess of 1,500 square feet in area (139.3546 m²) that generate combustible waste or use finely divided combustible materials.

Section 903.2.7 Group M. Is AMENDED to read:

1. A Group M *fire area* exceeds 5,000 square feet (464.5152 m²).
2. A Group M *fire area* is located more than two stories above grade plane.
3. The combined area of all Group M *fire areas* on all floors, including any mezzanines, exceeds 10,000 square feet (929.0304 m²).
4. A Group M occupancy used for the display and sale of upholstered furniture or mattresses exceeds 2,500 square feet (232.2576 m²).

Section 903.2.8 Group R. Is AMENDED to read:

An *automatic sprinkler system* shall be installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R-1, R-2, or R-4 *fire area*.

Section 903.2.8.2 AND Section 903.2.8.3 are COMBINED and AMENDED to read:

Section 903.2.8.2 Group R-3 or R-4 (Condition 1 or 2) congregate residencies.

An *automatic sprinkler system* shall be installed throughout all new Group R-3 or R-4 congregate residencies in accordance with Section 903.1.2 or 903.1.3 with 10 or fewer residents.

Existing Group R-3 or R-4 congregate residencies shall be retrofitted with an automatic sprinkler system in accordance with Section 903.1.2 or 903.1.3 within 24 months of discovery or annexation into Pinetop Fire District/Timber Mesa Fire and Medical District boundaries.



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

Section 903.2.9 Group S-1. Is AMENDED to read:

1. A Group S-1 *fire area* exceeds 5,000 square feet (464.5152 m²).
2. A Group S-1 *fire area* is located more than two stories above grade plane.
3. The combined area of all Group S-1 *fire areas* on all floors, including any mezzanines, exceeds 10,000 square feet (929.0304 m²).
4. A Group S-1 *fire area* is used for the storage of commercial motor vehicle where the *fire area* exceeds 2,500 square feet (232.2576 m²).

Section 903.2.9.1 Repair Garages. Is AMENDED to read:

1. Buildings having two or more stories above grade plane, including *basements*, with a *fire area* containing a repair garage exceeding 5,000 square feet (464.5152 m²).
2. Buildings not more than one story above grade plane, with a *fire area* containing a repair garage exceeding 5,000 square feet (464.5152 m²).
3. A Group S-1 *fire area* used for the repair of commercial motor vehicles where the *fire area* exceeds 2,500 square feet (232.2576 m²).

Section 903.2.9.2 is AMENDED to read:

Buildings and structures where the area for storage of tires exceeds 10,000 cubic feet (283.1685 m³) shall be equipped throughout with an *automatic sprinkler system* in accordance with Section 903.3.1.1.

Section 903.2.10 Group S-2. Is AMENDED to read:

1. Where the *fire area* of an enclosed parking garage exceeds 5,000 square feet (464.5152 m²).
- Exception: Is DELETED entirely**



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

Section 903.2.10.1. Is AMENDED to read.

An *automatic sprinkler system* shall be provided throughout buildings used for storage of commercial motor vehicle where the *fire area* exceeds 2,500 square feet (232.2576 m²).

Section 903.2.13 Group B. Is ADDED to read:

Group B. An automatic sprinkler system shall be installed throughout all new Group B Occupancies where the *fire area* exceeds 3,000 square feet (278.7091 m²).

Section 903.2.14 Mixed Occupancies Structures. Is ADDED to read:

All new buildings or structures which have the potential to be designated as a mixed occupancy shall have an *automatic sprinkler system* installed throughout. Existing buildings or structures, where a change of occupancy occurs, separation requirements shall comply with Table 508.4 of the International Building Code 2015, and Section 1103.5.4 of this code.

Section 903.4.2.1 Water-flow notification devices. Is ADDED to read:

Water-flow notification devices. An approved audible/visual notification appliance shall be installed in a normally occupied interior area of each building or each individual tenant space at the time of a tenant improvement. ADA restrooms within the same area shall have a visual notification appliance located within the room. Such sprinkler water flow notification devices shall be activated by the water flow of a single sprinkler of the smallest size installed in the system. This section will be retroactive as deemed necessary by the *fire code or building official*.



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

SECTION 905 - STANDPIPE SYSTEMS

Section 905.8 Dry standpipes. Is AMENDED to read:

When required by the fire code official, dry standpipes shall be installed when fire apparatus access roads do not meet the requirements as outlined in Appendix D.

Section 912 - FIRE DEPARTMENT CONNECTIONS

Section 912.2 Locations. Is AMENDED to read:

With respect to hydrants, driveways, buildings and landscaping, fire department connections shall be located that, the fire apparatus and hose connected to supply the system will not obstruct access to the buildings for other fire apparatus. The location of fire department connections shall be *approved* by the fire chief, or their designated fire code official.

CHAPTER 11

CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

SECTION 1103 - FIRE SAFETY REQUIREMENTS FOR EXISTING BUILDINGS

Section 1103.5.4 Fire area increase. Is ADDED to read:

Fire area Increase. An automatic sprinkler system shall be provided throughout existing buildings or residential occupancies where the square footage of the new fire area is greater than 25 percent of the total fire area of the existing structure and the required fire-flow for the total fire area (new & existing) is not equal to the fire-flow required by Appendix B of this code.



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

CHAPTER 53 – COMPRESSED GASES

SECTION 5307 - CARBON DIOXIDE (CO2) SYSTEMS USED IN BEVERAGE DISPENSING APPLICATIONS

Section 5307.5 Required protection. Is AMENDED to read:

Where carbon dioxide storage tanks, cylinders, piping and equipment are located indoors, rooms or areas containing carbon dioxide storage tanks, cylinders, piping and fittings and other areas where a leak of carbon dioxide can collect shall retroactively be provided with ventilation in accordance of Section 5307.5.1 and an emergency alarm system in accordance with Section 5307.5.2. Outside storage shall only require an emergency alarm in accordance with Section 5307.5.2.

APPENDIX D

FIRE APPARATUS ACCESS ROADS

SECTION D103 - MINIMUM SPECIFICATIONS

Section D103.1.1 Driveways. Is ADDED to read:

Driveways. Driveways exceeding 150 feet (45,720mm) in length providing access to single family dwelling units shall provide a minimum unobstructed width of 14 feet (4,267mm) and a minimum unobstructed height of 13 feet 6 inches (4,511mm). Driveways in excess of 150 feet (45,720mm) in length shall provide turnarounds. Driveways in excess of 200 feet (6,0960mm) in length and less than 20 feet (6,096mm) shall provide turnouts in addition to turnarounds. Driveway turnout shall be an all-weather road surface at least 10 feet (3,048mm) wide and 30



PINETOP FIRE DEPARTMENT

TIMBER MESA FIRE AND MEDICAL DISTRICT

feet (9,144mm) long. Driveway turnouts shall be located as required by the fire code official.

Driveway turnarounds shall have an inside turning radius of not less than 30 feet (9,144mm) and an outside turning radius of not less than 45 feet (13,716mm). Driveways that connect with a road or roads at more than one point may be considered as having a turnaround if all changes of direction meet the radius requirements for driveway turnarounds.

A driveway shall not serve in excess of five residential dwelling units.

Section D103.5 Fire apparatus access road gates. Is AMENDED to read:

1. Where a single gate is provided, the gate width shall be not less than 20 feet (6,096mm) when serving two or more directions. Where a fire apparatus road consists of a divided roadway, the gate shall not be less than 12 feet (3658 mm) when serving a single direction.
4. Emergency gates shall be equipped with a means of opening the gate by fire department personnel for emergency access. All electric gates shall be equipped with a key switch compatible with the fire district's existing system.

tion D103.5 Fire apparatus access road gates. Item 9 Is ADDED to read:

9. Existing electric gates shall be retrofitted with Knox key switch opening equipment in accordance with this section upon discovery or annexation into Pinetop Fire or Timber Mesa Fire and Medical District's boundaries. Compliance with this section shall be completed in a time schedule approved by the fire code official.



PINETOP FIRE DEPARTMENT
TIMBER MESA FIRE AND MEDICAL DISTRICT

Section D103.6 Signs. Is AMENDED to read:

Where required by the *fire code official*, fire apparatus access roads shall be marked with permanent NO PARKING - FIRE LANE signs complying with Pinetop Fire District/Town of Pinetop Lakeside or Timber Mesa Fire and Medical District/City of Show Low ordinances and or standards. Signs shall have a minimum dimension of 12 inches (305mm) wide by 18 inches (457mm) high and have red letters on white reflective background. Signs shall be posted on one or both sides of the fire apparatus access road as required by Section D103.6.1 through D103.6.2.

Section D103.6.2 Roads more than 26 feet in width. Is amended by adding a second paragraph:

Where parking lanes are provided, they shall have a minimum dimension of 8 feet (2,438mm) in width, measured from the back of a wedge or rolled curb, or from the face of a vertical curb.